

# REQUEST FOR QUOTATION AMENDMENT



## I. AMENDMENT

RFQ NO.	RFQ DATE	AMENDMENT NO.	AMENDMENT DATE
00040972	03/15/2016	001	03/24/2016
<b>ISSUED BY AND RETURN TO:</b> Washington River Protection Solutions, LLC P.O. Box 850 Richland, WA 99352 Attn: xx 509/376-9225 (tele)/376-0825 (fax) Alice_R_Hendrickson@rl.gov (e-mail) MSIN:B8-07		<b>DUE DATE</b> This amendment does not change the date by which offers are due unless a date and time is inserted below.	
		<b>DATE</b>  04-05-2016	<b>TIME</b>  8:00 A.M. PST

### DESCRIPTION OF AMENDMENT

Two items were omitted from the initial RFQ – Items 15 and 16 attached to this amendment

RFQ 40972

### QUESTIONS AND ANSWERS

Q: On drawing H-14-110144 Sheet 001 Rev 2 item 2 calls out either H-14-107367-10 or -20 but on that drawing H-14-107367 it only calls out -10. We believe it should be Stainless Steel, can you confirm this.

A: Yes, the top hat should be SST (assembly H-14-107367-020) to match the rest of the Tank Inlet Assembly. Attached is DCN-711440 that adds assembly -020 to drawing H-14-107367.

Q: Specification RPP-19407 is referenced on the drawing H-14-110144 but was not provided.

A: In lieu of providing RPP-19407 Engineering has provided the following: Leak Testing of the Vacuum Controller Assembly shall be a pressure decay test per ASME AG-1. The test pressure shall be 20 in. WG +5/-0 in. WG.

Q: Drawing H-14-021360 item 5 includes a note to see detail "A", Page 6 for typical flange assembly (3PLCS). Page 6 does not include a detail "A".

A: Page 6 does not provide the detail as stated it is on Page 7 of this drawing. See attached

Except as provided herein, all terms and conditions of the solicitation remain unchanged and in full force and effect.

## II. ACKNOWLEDGMENT OF AMENDMENT

Offerors must acknowledge receipt of this amendment in writing, by the date and time specified for proposal submissions or the revised Due Date above (if revised), whichever is later. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE DESIGNATED LOCATION BY THE SPECIFIED DATE AND TIME MAY RESULT IN REJECTION OF YOUR OFFER. If, by virtue of this amendment you wish to change your offer, such change must make reference to the solicitation and this amendment.

<b>NAME AND ADDRESS OF OFFEROR</b>	<b>NAME OF SIGNER</b>
	<b>TITLE OF SIGNER</b>
<b>OFFEROR</b> <i>(Signature of person authorized to sign)</i>	<b>DATE</b>